



Certificate of Compliance

Certificate: 2570724 (LR 17773-18)

Master Contract: 155201

Project: 2570724

Date Issued: April 24, 2013

Issued to: Venture Measurement Company LLC

150 Venture Blvd
Spartanburg, SC 29305
USA

Attention: Brian Jamieson

The products listed below are eligible to bear the CSA Mark shown



Dimcho Genov

Issued by: Dimcho Genov

PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

Roto-Bin-Dicator, level indicator, Model R-H; one single pole, double throw switch, rated 125, 250 or 480V ac; pilot duty 345VA, 115V ac or 690VA, 230V ac; motor rating 120Vac, 50/60 Hz, 5W. Enclosure Type 4X.

Roto-Bin-Dicator, level indicator, Model RA-H; two single pole, double throw switches, rated 125, 250 or 480V ac; pilot duty 345VA, 115V ac or 690VA, 230V ac; motor rating 120Vac, 50/60 Hz, 5W. Enclosure Type 4X.

Roto-Bin-Dicator, level indicator, Model RB-H; one single pole, double throw switch, rated 125, 250 or 480V ac; pilot duty 345VA, 115V ac or 690VA, 230V ac; motor rating 240Vac, 50/60 Hz, 5W or 277V ac, 60 Hz, 5W. Enclosure Type 4X.

Roto-Bin-Dicator, level indicator, Model RC-H; two single pole, double throw switches, rated 125, 250 or 480V ac; pilot duty 345VA, 115V ac or 690VA, 230V ac; motor rating 240Vac, 50/60 Hz, 5W or 277V ac, 60 Hz, 5W. Enclosure Type 4X.

Auto-Bin-Dicator, level indicators, Models AB-S, AB-R; one single pole, double throw switch, rated 125, 250 or 480V ac; pilot duty, 375VA, 125V ac or 750VA, 250V ac.

Liquid Level Bin-Dicator, liquid level indicator, Model GT-1; one single pole, double throw switch, rated 125, 250 or 480V ac; pilot duty, 375VA, 125V ac or 750VA, 250V ac.



Certificate: 2570724 (LR 17773-18)

Master Contract: 155201

Project: 2570724

Date Issued: April 24, 2013

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements